



THE LINE TERMINATION BOX SHALL BE MOUNTED NEAR THE CONTROLLER UNIT, EITHER INSIDE OR OUTSIDE, AS MAY BEST SUIT THE PARTICULAR INSTALLATION, BUT AS NEAR TO ONE ROD OF THE GROUNDING NETWORK AS POSSIBLE.

FROM THE CENTER GROUND LUG, OF THE LINE TERMINATION BOX (WHICH HAS SURGE ARRESTORS BUILT IN TO IT), RUN A #10, OR LARGER, BARE COPPER GROUND WIRE AND CONNECT IT TO ONE OF THE GROUNDING RODS, OF THE 3-ROD GROUNDING GRID. AVOID ANY SHARP "BENDS" OR "KINKS" IN THE WIRE.

**flow master**

## Line Termination Box Grounding TWC 50/100/200/500